



Proposed Code Change

State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 6-19-09

Code 48.1-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title International Residential Code		Edition 2009
Section number and title 401.3 Drainage		Page 71
Proponent Steve Dean	Title	
Address 9025 N River Rd. Indianapolis In 46240		Phone 317 846 3234
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input checked="" type="checkbox"/> Delete without substitution		
<p>Delete the last sentence of the exceptions: Impervious surfaces within 10 feet of the building foundation shall be sloped a minimum of 2% away from the building.</p>		
REASON AND FISCAL IMPACT		
<p>Reason: Deleting the last sentence will make the code the same as the 2003 IRC. This statement would make all house walks and steps have a 2% slope. This would not allow for an even connection to an exterior landing.</p> <p>Fiscal Impact: There is no fiscal impact.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		